

ACWA-TYR
Diary No. 175 DL-5-4-18

DELHI JAL BOARD

(GOVT. OF NCT DELHI)

QUALITY CONTROL ZONAL LABORATORY

TRANS YAMUNA REGION TAHIRPUR DELHI-110093.

NO: DJB/ACWA(TYR)/2018.....

Dated: 13-03-2018

Analysis report of D. J. B. supply sample collected from St. Joseph's Academy Savita Vihar, Delhi-92, for drinking purpose. M/S. Principal, St. Joseph's Academy. Letter No. NIL dated 20.03.2018.

Date of collection: 27-03-18

Challan No. 426

dated: 22-03-2018

S. NO.	PARTICULARS	UNITS	LIMITS	Result
PHYSICAL EXAMINATION				
1.	Colour	--	--	Clear
2.	Odour	--	--	Chlor.
3.	Turbidity	NTU	(1-5)	<2.0
4.	pH Value		(6.5 to 8.5)	7.6
5.	Electric Conductivity	Um/cm		202
6.	Total Dissolved Solids	Mg/l	(500-2000)	131
CHEMICAL EXAMINATION				
1.	Nitrate	Mg/l	(45)	
2.	Nitrite	"	--	NIL
3.	Ammonia	"	--	NIL
4.	Chloride	"	(250 - 1000)	10
5.	Fluoride	"	(1.0-1.5)	0.54
6.	Sulphate	"	(200-400)	25
7.	Free Carbon dioxide	"	"	4
8.	P ^H Alkalinity	"	"	NIL
9.	Total Alkalinity	"	(200-600)	48
10.	Total Hardness	"	(200-600)	80
12.	Calcium as (Ca)	"	(75-200)	21.6
13.	Magnesium (Mg)	"	(30-100)	6.24
14.	Residual Chlorine (DJB supply)	"	(0.2-1.0)	0.25
15.	Total Iron	"	(0.3)	0.12
Bacteriological Examination				
16.	Bacteriological Count	MPN/100ml	Absent	0

This Report Pertains To The Particular Sample Only

REMARKS : On the basis of tested parameters, the above water sample confirm the drinking water specifications BIS: 10500-2012 and fit for drinking purpose.

J. Singh
31/4/18
A/C Chemist

K. Singh
31/4/18
Chemist

[Signature]
31/4/18
ACWA(TYR)

Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyrr)
Tahir Pur Dilshad Garden, Delhi-93

D5zyrvw4



DELHI JAL BOARD: GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO. 208, VARUNALAYA PHASE-I
KAROL BAGH, NEW DELHI – 110005
23558264

No./DJB/EE(RWH/GWC)/2018/8291

Dated:- 07/12/18


To,

Principal,
St. Joseph's Academy,
Savita Vihar, Delhi-110092

Subject: Adequacy certificate in regard to rain water harvesting system at St. Joseph's Academy, Savita Vihar, Delhi-110092.

Please refer to your letter dated 30.11.2018 in which you have informed that Rain Water Harvesting has been installed at your said premises, the rain water harvesting structure was inspected by NGT Joint Inspection Team on dated 05.12.2018 and found sufficient and adequate to harvest the catchment area of your premises.

You are therefore advised to keep are RWH system neat & clean and maintain the same periodically.


EE (RWH/GWC)
EE (G W CELL)
DELHI JAL BOARD
VARUNALAYA BHAWAN,
JHANDEWALLAN, N.D.-05

